



## Setting Electroline Pump Numbers

Issued 13/11/2015

| Pump # | On=Closed | Off=Open  |           |           |
|--------|-----------|-----------|-----------|-----------|
|        | Sw1       | Sw2       | Sw3       | Sw4       |
| 16     | On=Closed | On=Closed | On=Closed | On=Closed |
| 1      | Off=Open  | On=Closed | On=Closed | On=Closed |
| 2      | On=Closed | Off=Open  | On=Closed | On=Closed |
| 3      | Off=Open  | Off=Open  | On=Closed | On=Closed |
| 4      | On=Closed | On=Closed | Off=Open  | On=Closed |
| 5      | Off=Open  | On=Closed | Off=Open  | On=Closed |
| 6      | On=Closed | Off=Open  | Off=Open  | On=Closed |
| 7      | Off=Open  | Off=Open  | Off=Open  | On=Closed |
| 8      | On=Closed | On=Closed | On=Closed | Off=Open  |
| 9      | Off=Open  | On=Closed | On=Closed | Off=Open  |
| 10     | On=Closed | Off=Open  | On=Closed | Off=Open  |
| 11     | Off=Open  | Off=Open  | On=Closed | Off=Open  |
| 12     | On=Closed | On=Closed | Off=Open  | Off=Open  |
| 13     | Off=Open  | On=Closed | Off=Open  | Off=Open  |
| 14     | On=Closed | Off=Open  | Off=Open  | Off=Open  |
| 15     | Off=Open  | Off=Open  | Off=Open  | Off=Open  |

Pump # may be confirmed via "switch test mode" function "0" "0" "0" "4" on thumb wheels